SIEMENS

Data sheet

3UG4616-1CR20



Digital monitoring relay for 3-phase voltage with N-conductor Phase sequence can be activated Phase failure 3 x 90 to 400 V 50 to 60 Hz AC Undervoltage and overvoltage 90-400 V Hysteresis 1-20 V 0-20 s each for Umin and Umax 1 CO for Umin 1 CO for Umax screw terminal Successor product for 3UG3042-1BP50

Figure si	imilar
-----------	--------

product brand name	SIRIUS
product designation	Network monitoring relay with digital setting
design of the product	5 functions
product type designation	3UG4
General technical data	
product function	Phase monitoring relay
display version LED	No
design of the display	LCD
insulation voltage for overvoltage category III according to IEC 60664	
 with degree of pollution 3 rated value 	690 V
degree of pollution	3
type of voltage	
 for monitoring 	AC
 of the control supply voltage 	AC
surge voltage resistance rated value	6 kV
protection class IP	IP20
shock resistance acc. to IEC 60068-2-27	sinusoidal half-wave 15g / 11 ms
vibration resistance acc. to IEC 60068-2-6	1 6 Hz: 15 mm, 6 500 Hz: 2g
mechanical service life (switching cycles) typical	10 000 000
electrical endurance (switching cycles) at AC-15 at 230 V typical	100 000
thermal current of the switching element with contacts maximum	5 A
reference code acc. to IEC 81346-2	К
relative repeat accuracy	1 %
Substance Prohibitance (Date)	01.05.2012
Product Function	
product function	
 undervoltage detection 	Yes
 overvoltage detection 	Yes
 phase sequence recognition 	Yes
 phase failure detection 	Yes
 asymmetry detection 	Yes
 overvoltage detection 3 phase 	Yes
 undervoltage detection 3 phases 	Yes
 voltage window recognition 3 phase 	Yes
 adjustable open/closed-circuit current principle 	Yes
auto-RESET	Yes


Control circuit/ Control control supply voltage at AC • at 50 Hz rated value 90 400 V • at 60 Hz rated value 90 400 V	
• at 50 Hz rated value 90 400 V	
operating range factor control supply voltage rated value at AC at 50 Hz	
• initial value 1	
• full-scale value 1	
operating range factor control supply voltage rated value at AC at 60 Hz	
• initial value 1	
• full-scale value 1	
Measuring circuit	
adjustable response delay time	
with lower or upper limit violation 0.1 20 s	
accuracy of digital display +/-1 digit	
Precision	
relative metering precision 5 %	
Auxiliary circuit	
number of NC contacts delayed switching 0	
number of NO contacts delayed switching 0	
number of CO contacts delayed switching 2	
operating frequency with 3RT2 contactor maximum 5 000 1/h	
Main circuit	
number of poles for main current circuit 3	
ampacity of the output relay at AC-15	
• at 250 V at 50/60 Hz 3 A	
• at 400 V at 50/60 Hz 3 A	
ampacity of the output relay at DC-13	
• at 24 V 1 A	
• at 125 V 0.2 A	
• at 250 V 0.1 A	
operational current at 17 V minimum 5 mA	
continuous current of the DIAZED fuse link of the 4 A output relay	
Electromagnetic compatibility	
conducted interference	
• due to burst acc. to IEC 61000-4-4 2 kV	
due to conductor-earth surge acc. to IEC 61000-4-5 2 kV	
due to conductor-conductor surge acc. to IEC 1 kV	
field-based interference acc. to IEC 61000-4-3 10 V/m	
electrostatic discharge acc. to IEC 61000-4-2 6 kV contact discharge / 8 kV air disch	harge
Galvanic isolation	
galvanic isolation	
between input and output Yes	
between the outputs Yes	
between the voltage supply and other circuits Yes	
Connections/ Terminals	
product component removable terminal for auxiliary Yes and control circuit	
type of electrical connection screw-type terminals	
type of connectable conductor cross-sections	
• solid 1x (0.5 4 mm2), 2x (0.5 2.5 mm2	,
• finely stranded with core end processing 1x (0.5 2.5 mm2), 2x (0.5 1.5 mm	n2)
• at AWG cables solid 2x (20 14)	
• at AWG cables stranded 2x (20 14)	
connectable conductor cross-section	
• solid 0.5 4 mm ²	
• finely stranded with core end processing 0.5 2.5 mm ²	

section		ctor cross				
 solid 			20 14			
 stranded 			20 14			
tightening torque with			0.8 1.2 N·m			
Installation/ mounting	/ dimensions					
mounting position			any			
fastening method		snap-on mounting				
height		102 mm				
width		22.5 mm				
depth			91 mm			
required spacing	a mounting					
 with side-by-sid — forwards 	emounting		0 mm			
— backwards	2		0 mm			
- upwards	1		0 mm			
— downward	\$		0 mm			
— at the side		0 mm				
 for grounded pa 			•			
— forwards			0 mm			
— backwards	3		0 mm			
— upwards			0 mm			
– at the side			0 mm			
- downward	s		0 mm			
 for live parts 						
— forwards			0 mm			
— backwards	;		0 mm			
— upwards			0 mm			
- downward	S		0 mm			
— at the side			0 mm			
Ambient conditions						
installation altitude at	height above sea level m	naximum	2 000 m			
ambient temperature						
	 during operation 		-25 +60 °C			
during storage			-40 +85 °C			
 during transport 			-40 +85 °C			
Certificates/ approval	S					
General Product Ap	proval		EMC	Declaration of Conformity	Test Certificates	
			A		Type Test Certific-	
	(Ψ	FAL	Æ	CE	<u>Type Test Certific-</u> ates/Test Report	
	(ل) س	EAC	RCM	C E EG-Konf.	Type Test Certific- ates/Test Report	
	U	EAC	RCM	CE	<u>Type Test Certific-</u> ates/Test Report	
		EAC	RCM	CE	<u>Type Test Certific-</u> ates/Test Report	
CCC Test Certificates	UL Marine / Shipping	EAC	CCM other	CE	<u>Type Test Certific-</u> ates/Test Report	
ccc Test Certificates	UL Marine / Shipping	EAC	RCM	EG-Konf. Railway	<u>Type Test Certific-</u> ates/Test Report	
	Marine / Shipping	EAC	RCM	C C EG-Konf.	<u>Type Test Certific-</u> ates/Test Report	
CCC Test Certificates Special Test Certific-	Hoyd's Register		RCM	EG-Konf. Railway	<u>Type Test Certific-</u> ates/Test Report	
CCC Test Certificates Special Test Certific-	Marine / Shipping		RCM	EG-Konf. Railway	<u>Type Test Certific-</u> ates/Test Report	
CCC Test Certificates Special Test Certific-	Hoyd's Register		RCM	EG-Konf. Railway	<u>Type Test Certific-</u> ates/Test Report	
CCC Test Certificates Special Test Certific-	Hoyd's Register		RCM	EG-Konf. Railway	<u>Type Test Certific-</u> ates/Test Report	
CCC Test Certificates Special Test Certific-	Hoyd's Register		RCM	EG-Konf. Railway	<u>Type Test Certific-</u> ates/Test Report	
Test Certificates Special Test Certificates Special Test Certificates Eurther information	Lipydis Register Lins wnloadcenter (Catalogs		RCM other Confirmation	EG-Konf. Railway	<u>Type Test Certific-</u> ates/Test Report	
Test Certificates Special Test Certificates Special Test Certificates Information- and Do https://www.siemens.	Liss wnloadcenter (Catalogs		RCM other Confirmation	EG-Konf. Railway	Type Test Certific- ates/Test Report	
Test Certificates Special Test Certificates Special Test Certificates Information and Do https://www.siemens Industry Mall (Online)	unloadcenter (Catalogs com/ic10 e ordering system)	s, Brochures,	RCM other Confirmation	EG-Konf. Railway	Type Test Certific- ates/Test Report	
Test Certificates Special Test Certificates Special Test Certificates Information Information- and Do https://www.siemens Industry Mall (Online https://mall.industry.si Cax online generato	wnloadcenter (Catalogs com/ic10 e ordering system) iemens.com/mall/en/en/C	s, Brochures,	RCM other Confirmation	Railway Vibration and Shock	<u>Type Test Certificates/Test Report</u>	

Service&Support (Manuals, Certificates, Characteristics, FAQs,...) https://support.industry.siemens.com/cs/ww/en/ps/3UG4616-1CR20

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3UG4616-1CR20&lang=en **Characteristic: Derating**

https://support.industry.siemens.com/cs/ww/en/ps/3UG4616-1CR20/manual



last modified:

12/18/2020 🖸