



Main

Range	Vigirex
Device short name	PA50
Product or component type	Earth leakage current sensor
Device application	Equipment monitoring and control
Range compatibility	Vigirex RH plug-in relay
[Ie] rated operational current	85 A

Complementary

Current sensor type	A type closed toroid
Network type	AC DC
Network frequency	45...440 Hz
[Ui] rated insulation voltage	1000 V
Transformer ratio	1/1000
[Icw] rated short-time withstand current	100 kA for 0.5 s
Residual short-circuit withstand current	85 kA / 0.5 s conforming to IEC 60947-2
Overvoltage category	IV
[Uimp] rated impulse withstand voltage	12 kV
Mounting mode	Fixed (plain backplate) Fixed (profiled sheet metal) Fixed (slotted backplate) Clip-on (DIN rail) Clip-on (Vigirex relay)
Calorific value	1.42 MJ
Connections - terminals	Screw connection 0.22 mm ²
Diameter	50 mm inner:
Cable outer diameter	25 mm: 50 mm ² (maximum)
Net weight	0.2 kg

Height	108 mm
Width	88 mm
Depth	29 mm

Environment

IP degree of protection	Connectors: IP20 IP30
Environmental characteristic	Exposure to damp heat not in service (25...55 °C, RH 95 %) : 28 cycles conforming to IEC 60068-2-30 Salt mist: Kb/2 conforming to IEC 60068-2-52 Exposure to damp heat in service: category C2: 48 hours conforming to IEC 60068-2-56
Pollution degree	Level 3 conforming to IEC 60664-1
Ambient air temperature for operation	-35...70 °C
Ambient air temperature for storage	-55...85 °C

Offer Sustainability

Sustainable offer status	Green Premium product
REACH Regulation	REACH Declaration
EU RoHS Directive	Pro-active compliance (Product out of EU RoHS legal scope) EU RoHS Declaration
Mercury free	Yes
RoHS exemption information	Yes
China RoHS Regulation	China RoHS declaration Product out of China RoHS scope. Substance declaration for your information
Environmental Disclosure	Product Environmental Profile
Circularity Profile	End of Life Information
WEEE	The product must be disposed on European Union markets following specific waste collection and never end up in rubbish bins

Contractual warranty

Warranty	18 months
----------	-----------